

<b>Issued to:</b>	PROSOFT TECHNOLOGY INC 3RD FL 5201 TRUXTUN AVE BAKERSFIELD CA 93309
<b>This is to certify that representative samples of</b>	PROGRAMMABLE CONTROLLERS FOR USE IN HAZARDOUS LOCATIONS See next page for models
	Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
<b>Standard(s) for Safety:</b>	USL - ANSI/ISA 12.12.01-2012, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Division 1 and 2 Hazardous (Classified) Locations. USL - UL 508, Industrial Control Equipment. CNL - CSA C22.2 No. 213-M1987, Non-incendive Control Equipment for Use in Class I, Division 2 Hazardous Locations. CNL - CSA C22.2 No. 142-M1987, Process Control Equipment.
<b>Additional Information:</b>	See the UL Online Certifications Directory at <a href="http://www.ul.com/database">www.ul.com/database</a> for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Programmable Logic Controllers PLX3x Gateway Series Modules where x can be 1 or 2, followed by EIP or MBTCP or MBS or MBS(4), Followed by MBS, MBS4, ASCII, ASCII4, DF1(4), DF1, 104, BACNET, EGD, DNPNET, DNPSNET, 61850S, 101, DNP, and SIE, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

Programmable Logic Controllers PLX8x Gateway Series Modules where x can be 1 or 2, followed by EIP or MNET, Followed by 61850, Followed by Series A or B, for use in Class I, Division 2, Groups A, B, C and D Hazardous Locations.

