

Certificate

PROFIBUS Nutzerorganisation e.V. grants to

ProSoft Technology

9201 Camino Media, Suite 200, 93311 Bakersfield, CA, USA

the Certificate No: **Z11199** for the PROFINET IO Device:

Model Name: PLX32-EIP-PND
 Revision: SW/FW: 1.005.035; HW: 1
 Identnumber: 0x0175; 0x8202
 GSD: GSDML-V2.3-ProSoft-PLX32-EIP-PNDevice-V3.10-20171113.xml
 DAP: DIM 1, 0x80000000

This certificate confirms that the product has successfully passed the certification tests with the following PROFINET scope:

<input checked="" type="checkbox"/> Hardware	Auto_Negotiation, Auto_Polarity, Auto_Crossover
<input checked="" type="checkbox"/> Conformance Class A	RT_CLASS_1, RT_CLASS_2, RTA, LLDP

Test Report Number: PN182-1 plus Manufacturer Declaration
 Authorized Test Laboratory: PROFI Interface Center, Johnson City, USA

The tests were executed in accordance with the following documents:
 "Test Specifications for PROFINET IO devices, Version 2.2.4 from December 2010" and
 "Test Cases for PN-Tester for PROFINET IO devices, Version 2.2.4.16.21".

This certificate is granted according to the document:
 "Framework for testing and certification of PROFIBUS and PROFINET products".


For all products that are placed in circulation by **April 27, 2027** the certificate is valid for life.

Karlsruhe, February 04, 2025


Board of PROFIBUS Nutzerorganisation e. V.



(Official in Charge)



(Xaver Schmidt)

(Frank Moritz)